



ZIMBABWE ELECTRICITY TRANSMISSION & DISTRIBUTION COMPANY

HEAD OFFICE
ELECTRICITY CENTRE,
25 SAMORA MACHEL AVENUE,
HARARE
P.O. BOX 377, HARARE
TELEPHONE: 774491/9, 774508/35
FAX: 774542/3, 758356

OUR REF:..... FN/ec

YOUR REF

WHEN CALLING WITH REFERENCE
TO THIS LETTER PLEASE ASK FOR

..... F. Nyamakambo.....

17 June 2022

To All Bidders

Dear Sir/Madam

CLARIFICATION NO. 1 TO TENDER NO. ZETDC/INTER/04/2022 FOR SUPPLY AND DELIVERY OF 11KV SF6/VACUUM INSULATED RING MAIN UNITS (RMU)

The above subject matter refers.

Kindly find attached **Clarification No. 1** in response to a query raised by a participating bidder for Tender No. ZETDC/INTER/04/2022 for Supply and Delivery of 11kV Sf6/Vacuum Insulated Ring Main Units (RMU).

Yours faithfully

F. NYAMAKAMBO
SUPPLY CHAIN MANAGER

TENDER NO. ZETDC/INTER/04/2022 FOR SUPPLY AND DELIVERY OF 11KV SF6/VACUUM INSULATED RING MAIN UNITS (RMU)

CLARIFICATION NO. 1

Item	Description/Query from Bidder	ZETDC Response
1.	<p>On page 13, Part 2, Statement of Requirements the Description of Goods is:</p> <p>Item No. 1, Ring Main Units 11kV 2 Way</p> <p>Item No. 2, Ring Main Units Non Extensible 11kV 3 Way</p> <p>However on page 18, General Description, Clause 2.1, RMU Configuration of Cables (C) and Transformer (T) Terminals the single line drawing is 3 Way and 4 Way. Please clarify this and advise the following:</p> <p>For 2 Way RMU: How many load break switches? How many transformer feeders? Is it indoor RMU or outdoor RMU?</p> <p>For 3 Way RMU: How many load break switches? How many transformer feeders? Is it indoor RMU or outdoor RMU?</p>	<p>The C+T+C is what we are referring to as the two way. Two load break switches & one transformer wing.</p> <p>The C+C+T +C is what we are referring to as the 3 way , with three wings having the three load break switches and one transformer wing</p> <p>2 load break switches for 2 Way RMU 1 transformer feeder Indoor RMU</p> <p>3load break switches for 3Way RMU 1 transformer Feeder Indoor</p>

ZETDC H/O PROCUREMENT

17 JUN 2022

2nd Floor, Southwing, Electricity Centre
 25 S. Machel Avenue, Harare
 Tel: 0242 750262
 procurement@zetdc.co.zw