



ZIMBABWE ELECTRICITY TRANSMISSION & DISTRIBUTION COMPANY

HEAD OFFICE
ELECTRICITY CENTRE,
25 SAMORA MACHEL AVENUE,
HARARE
P.O. BOX 377, HARARE
TELEPHONE: 774491/9, 774508/35
FAX: 774542/3, 758356

OUR REF:..... FN/ec

YOUR REF

WHEN CALLING WITH REFERENCE
TO THIS LETTER PLEASE ASK FOR

..... F. Nyamakambo.....

21 October 2022

To All Bidders

Dear Sir/Madam

CLARIFICATION NO. 1 TO TENDER NO. ZETDC/INTER/15/2022 FOR THE SUPPLY, DELIVERY AND INSTALLATION OF PRINCE EDWARD DAM 20MVA, 33/11KV TRANSFORMER AND ACCESSORIES

The above subject matter refers.

Kindly find attached **Clarification No. 1** in response to queries raised by participating bidders for Tender No. ZETDC/INTER/15/2022 for the Supply, Delivery and Installation of Prince Edward Dam 20MVA, 33/11kV Transformer and Accessories.

Yours faithfully

F. NYAMAKAMBO
SUPPLY CHAIN MANAGER

TENDER NO. ZETDC/INTER/15/2022 FOR THE SUPPLY, DELIVERY AND INSTALLATION OF PRINCE EDWARD DAM 20MVA, 33/11KV TRANSFORMER AND ACCESSORIES

CLARIFICATION NO. 1

Item	Description/Query from Bidder	ZETDC Response
1.	With reference to tender number ZETDC/INTER/15/2022, Supply, Delivery and Installation of Prince Edward Dam 20MVA 33/11-KV-Transformer and Accessories. We are seeking for clarity on the tapping range with reference to the Voltage range for any equipment, it seems contrary, please clarify and confirm.	Tapping Range (+4/-11x1.25%) HV, Extreme plus tapping 34.65KV HV, Extreme minus tapping 28.46kv (Refer to revision on table below)

Item	Description	Unit	User's Requirement	Bidder's Offer	Reference page in technical brochure (e.g. found on page 3, section 3.2 paragraph/line etc.)
54.8	Tapping Range		(+4/-11x1.25%)		
54.9 (a)	HV, Extreme plus tapping	kV	34.65		
54.9 (b)	HV, Extreme minus tapping	kV	28.46		

N.B. The above schedule/table with Item No.s 54.8, 54.9 (a) and 54.9 (b) is part of the **TECHNICAL GUARANTEE SCHEDULE: 20 MVA, 33/11KV Power Transformer**, Clause 9.1 on page 61 of the Standard Bidding Document (SBD).

