



## ZIMBABWE ELECTRICITY TRANSMISSION & DISTRIBUTION COMPANY

HEAD OFFICE  
ELECTRICITY CENTRE,  
25 SAMORA MACHEL AVENUE,  
HARARE  
P.O. BOX 377, HARARE  
TELEPHONE: 774491/9, 774508/35  
FAX: 774542/3, 758356

OUR REF:..... FN/ec .....

YOUR REF .....

WHEN CALLING WITH REFERENCE  
TO THIS LETTER PLEASE ASK FOR

..... F. Nyamakambo.....

15 December 2022

### To All Bidders

Dear Sir/Madam

### CLARIFICATION NO. 2 FOR TENDER NO. ZETDC/INTER/16/2022 FOR THE SUPPLY AND DELIVERY OF CABLES AND CONDUCTORS.

The above subject matter refers.

Following closing date extension for the above mentioned tender, kindly find attached **Clarification No. 2** to Tender No. ZETDC/INTER/16/2022 for the Supply and Delivery of Cables and Conductors.

Kindly note that the **deadline date for submission of queries** has been extended from the 2<sup>nd</sup> of December 2022 to the **20<sup>th</sup> of December 2022** following issuance of additional technical specification under Addendum No. 3 to the Standard Bidding Document (SBD).

The tender closing date remains **10 January 2023 at 10:00 hours** as per closing date extension letter uploaded on ZETDC website on 09 December 2022.

Yours faithfully

**F. NYAMAKAMBO**  
**SUPPLY CHAIN MANAGER**

TENDER NO. ZETDC/INTER/16/2022 FOR THE SUPPLY AND DELIVERY OF CABLES AND CONDUCTORS

CLARIFICATION NO. 2

Item	Description/Query from Bidder	ZETDC Response
1.	<p>Technical Specification, page 29: The potential tenders are requested to provide the price for 50 sq.mm HAD Conductor and 100 sq.mm HAD Conductor.</p> <p>However, the specification for 50 sq.mm HAD Conductor is <u>missing</u>.</p>	<p>Pursuant to the postponement of the closing date of the tender to <b>10 January 2023 at 10:00 hours</b>, kindly find attached the specification for Hard Drawn Aluminium Conductor that was missing in the Standard Bidding Document on ZETDC website for International Tenders under <b>Addendum No. 3</b> to Tender No. ZETDC/INTER/16/2022.</p>
2.	<p>On page 5 of 68 number 23 it states that the tender requires Type test reports but our suppliers (manufacturers) are saying cables and conductors does not include type test reports.</p>	<p>Type test reports are required for all equipment in line with Part 1: Bidding Procedures, Item 23 on page 4 of the SBD which clearly states that <i>“Results of Type tests or type test reports carried out by an independent Technical Institute on previously manufactured Cables and Conductors must be submitted with the bid and in English”</i></p> <p>For cables and conductor tests, bidders should refer to the standards below:</p> <p><b>For Cables</b>                      IEC60502 For cables below 30kV                      IEC60840 for cables rated above 30kV to 150kV                      IEC62067 for cables rated above 150kV</p> <p><b>For ASCR</b>                      IEC1089/BS215                      IEC889/888                      IS1521-1991</p>

