



ZIMBABWE ELECTRICITY TRANSMISSION & DISTRIBUTION COMPANY

HEAD OFFICE
ELECTRICITY CENTRE,
25 SAMORA MACHEL AVENUE,
HARARE
P.O. BOX 377, HARARE
TELEPHONE: 774491/9, 774508/35
FAX: 774542/3, 758356

OUR REF:..... FN/ec

YOUR REF

WHEN CALLING WITH REFERENCE
TO THIS LETTER PLEASE ASK FOR

..... F. Nyamakambo.....

15 June 2023

To All Bidders

Dear Sir/Madam

CLARIFICATION NO. 3 TO TENDER NO. ZETDC/INTER/01/2023 FOR THE DESIGN, MANUFACTURE, SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF 175MVA, 330/132/11KV POWER TRANSFORMER AT ALASKA 330KV SUBSTATION.

The above subject matter refers.

Kindly find attached **Clarification No. 3**, being additional information for Tender No. ZETDC/INTER/01/2023 for the Design, Manufacture, Supply, Delivery, Installation and Commissioning of 175MVA, 330/132/11kV Power Transformer at Alaska 330kV Substation.

Yours faithfully

F. NYAMAKAMBO
SUPPLY CHAIN MANAGER

TENDER NO. ZETDC/INTER/01/2023 FOR THE DESIGN, MANUFACTURE, SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF 175MVA, 330/132/11KV POWER TRANSFORMER AT ALASKA 330KV SUBSTATION

CLARIFICATION NO. 3

BASIC TECHNICAL DESCRIPTION OF THE REQUIRED POWER TRANSFORMER

Item	Description	ZETDC Clarification																
1.	Additional Information from ZETDC	<p>The transformer will operate in parallel with other transformers in the network. Hence, additional information for % impedance for the required transformer is as per the following minimum technical specifications:</p> <table border="1"> <thead> <tr> <th>Item</th> <th>Description</th> <th colspan="2">Technical Details</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Impedance, %Z</td> <td>Max Tap position</td> <td>9.6%</td> </tr> <tr> <td></td> <td></td> <td>Nominal tap position</td> <td>9.8%</td> </tr> <tr> <td></td> <td></td> <td>Minimum Tap position</td> <td>11.1%.</td> </tr> </tbody> </table>	Item	Description	Technical Details		1	Impedance, %Z	Max Tap position	9.6%			Nominal tap position	9.8%			Minimum Tap position	11.1%.
Item	Description	Technical Details																
1	Impedance, %Z	Max Tap position	9.6%															
		Nominal tap position	9.8%															
		Minimum Tap position	11.1%.															

ZETDC H/O PROCUREMENT
 15 JUN 2023
 2nd Floor, Southwing, Electricity Centre
 25 S. Machea Avenue Harare
 Tel: 0242 750262
 procurement@zetdc.co.zw
[Signature]