



ZIMBABWE ELECTRICITY TRANSMISSION & DISTRIBUTION COMPANY

HEAD OFFICE
ELECTRICITY CENTRE,
25 SAMORA MACHEL AVENUE,
HARARE
P.O. BOX 377, HARARE
TELEPHONE: 774491/9, 774508/35
FAX: 774542/3, 758356

OUR REF FN/pt
YOUR REF
WHEN CALLING WITH REFERENCE
TO THIS LETTER PLEASE ASK FOR

F. Nyamakambo

4 August 2023

To all bidders

RE: CLARIFICATION OF ZETDC/DOM/39/2023: SUPPLY AND DELIVERY OF INSULATORS

Query 1: We are kindly requesting for clarification for the above items. Page 13 on item No.1 it reads "Insul. Disc Porcelain 254mm DIA 10000 LB" whereas on Page 19 under the Technical Guarantee Schedule, first row, the Insulators materials stated polymeric. Please clarify which material of insulators is needed.

Response 1: The tender is for the supply and delivery of Polymeric Suspension Insulators for 11KV and 33KV.

For the 0.4KV shackle Insulators, the material is porcelain. Attached is an additional TGS for the shackle Insulators.

Item	Description	Unit	Required	Actual
1	Material		Porcelain	
2	Nominal Voltage	kV	0.4	
3	Min Neck and Hole Diameter	mm	12	
4	Suitable for Conductors of Diameter 5 - 15mm		Yes	

Yours faithfully,

F. NYAMAKAMBO
SUPPLY CHAIN MANAGER