



## ZIMBABWE ELECTRICITY TRANSMISSION & DISTRIBUTION COMPANY

HEAD OFFICE  
ELECTRICITY CENTRE,  
25 SAMORA MACHEL AVENUE,  
HARARE  
P.O. BOX 377, HARARE  
TELEPHONE: 774491/9, 774508/35  
FAX: 774542/3, 758356

OUR REF:..... FN/ec .....

YOUR REF .....

WHEN CALLING WITH REFERENCE  
TO THIS LETTER PLEASE ASK FOR

..... F. Nyamakambo.....

06 October 2023

### To All Bidders

Dear Sir/Madam

**ADDENDUM NO. 2 TO THE SBD: REVISED PART 2, STATEMENT OF REQUIREMENTS – LIST OF GOODS AND PRICE SCHEDULE & REVISED DELIVERY SCHEDULE FOR TENDER NO. ZETDC/INTER/06/2023 FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF 20MVA, 132/88/11KV POWER TRANSFORMER AT GLENVILLE 88/11KV SUBSTATION**

The above subject matter refers.

Attached herewith is **Addendum No. 2 to the Standard Bidding Document (SBD)** for Tender No. ZETDC/INTER/06/2023 for the Supply, Delivery, Installation and Commissioning of 20MVA, 132/88/11kV Power Transformer at Glenville 88/11kV Substation relating to **revised Part 2, Statement of Requirements – List of Goods and Price Schedule on page 13 of 110 in the SBD and revised Delivery Schedule on page 14 of 110 in the SBD.**

Yours faithfully

**F. NYAMAKAMBO**  
**SUPPLY CHAIN MANAGER**

# ZIMBABWE ELECTRICITY TRANSMISSION & DISTRIBUTION COMPANY



## ADDENDUM NO. 2

**TO STANDARD BIDDING DOCUMENT (SBD) FOR  
TENDER NO. ZETDC/INTER/06/2023**

**FOR THE SUPPLY, DELIVERY, INSTALLATION AND  
COMMISSIONING OF 20MVA, 132/88/11KV POWER  
TRANSFORMER AT GLENVILLE 88/11KV  
SUBSTATION**

*(REVISED PART 2: STATEMENT OF REQUIREMENTS – LIST OF GOODS AND PRICE  
SCHEDULE ON PAGE 13 OF 110 IN THE STANDARD BIDDING DOCUMENT & REVISED  
DELIVERY SCHEDULE ON PAGE 14 OF 110 IN THE STANDARD BIDDING DOCUMENT)*

ZETDC H/O PROCUREMENT

06 OCT 2023

2nd Floor, Sunning, Electricity Centre  
25 S. Machel Avenue, Harare  
Tel: 0242 750262  
procurement@zetdc.co.zw

fwd

**Part 2: STATEMENT OF REQUIREMENTS****2.1 List of Goods and Price Schedule**

Procurement Reference Number:

ZETDC/INTER/06/2023

Bidder's Name:

\_\_\_\_\_

Bidder's Reference Number:

\_\_\_\_\_

Currency of Bid - USD

Item No	Description of Goods	UOM	Qty	Unit Price Excl. Duty & VAT	Total Price
				[to be provided by the Bidder]	[to be provided by the Bidder]
1	20MVA, 132/88/11kV Power Transformer (complete with spares)	Each	1		
2	11kV Lighting Arrestors (Station Type)	Each	3		
3	<b>16 Panel 11kV Indoor Switchgear Board:</b>				
	Transformer Panel complete with Circuit Breaker rated 2000 continuous current, VTs, CTs with respective relays (OC & EF, Metering, differential, REF, metering). Circuit Breaker to be SCADA operated with Multi-Function Configurable Electrical Transducer.	Each	3		
	Bus Section Panel complete with Circuit Breaker rated 2000 continuous current, Vs, CTs, with respective relays (OC & EF, Metering). Circuit Breaker to be SCADA operated with Multi-Function Configurable Electrical Transducer.	Each	1		
	Feeder Panel complete with Circuit Breaker rated 1,600Amp continuous current complete with VTs, CTs, respective Relays (over current and earth fault, sensitive earth fault, auto-reclosing, lockout relay, event logging), ammeter and thermal maximum demand ammeter, secondary fuses and any necessary auxiliary contactors and secondary terminals, fully wired. Circuit Breaker to be SCADA operated with Multi-Function Configurable Electrical Transducer.	Each	12		
	Statistical Metering Panel measurands to be SCADA monitored with Multi-Function Configurable Electrical Transducer.	Each	1		
	Spare 11kV Feeder Circuit Breaker	Each	1		
	<b>Sub-Total (1) Excluding Duty and VAT</b>				
	<b>Duty</b>				
	<b>Sub-Total (2) Including Duty</b>				
	<b>VAT (15%)</b>				
	<b>Total Tender Price Including Duty and VAT</b>				

## 2.2 Delivery Schedule

Procurement Reference No.:

ZETDC/INTER/06/2023

Bidder's Name:

Bidder's Reference Number:



{Note to Bidders: If the delivery period offered, or any other details, differ from the requirements below, this should be stated in your tender}.

Item No.	Description of Goods	Qty	UOM	Delivery Required by Procuring Entity and applicable INCOTERM	Date by Entity applicable	Bidder's offered Delivery period & Incoterm
						<i>N.B. Insert Delivery Period &amp; Applicable Incoterm in the row below under this column</i>
1	20MVA, 132/88/11kV Power Transformer (complete with spares)	1	Each	5 Months or better; CIP Glenville Substation, Bulawayo		
2	11kV Lighting Arrestors (Station Type)	3	Each	5 Months or better; CIP Glenville Substation, Bulawayo		
3	16 Panel 11kV Indoor Switchgear Board					
	Transformer Panel complete with Circuit Breaker rated 2000 continuous current, VTs, CTs with respective relays (OC & EF, Metering, differential, REF, metering). Circuit Breaker to be SCADA operated with Multi-Function Configurable Electrical Transducer.	3	Each	5 Months or better; CIP Glenville Substation, Bulawayo		
	Bus Section Panel complete with Circuit Breaker rated 2000 continuous current, Vs, CTs, with respective relays (OC & EF, Metering). Circuit Breaker to be SCADA operated with Multi-Function Configurable Electrical Transducer.	1	Each	5 Months or better; CIP Glenville Substation, Bulawayo		

	Feeder Panel complete with Circuit Breaker rated 1,600Amp continuous current complete with VTs, CTs, respective Relays (over current and earth fault, sensitive earth fault, auto-reclosing, lockout relay, event logging), ammeter and thermal maximum demand ammeter, secondary fuses and any necessary auxiliary contactors and secondary terminals, fully wired. Circuit Breaker to be SCADA operated with Multi-Function Configurable Electrical Transducer.	12	Each	5 Months or better; CIP Glenville Substation, Bulawayo	
	Statistical Metering Panel measurands to be SCADA monitored with Multi-Function Configurable Electrical Transducer.	1	Each	5 Months or better; CIP Glenville Substation, Bulawayo	
	Spare 11kV Feeder Circuit Breaker	1	Each	5 Months or better; CIP Glenville Substation, Bulawayo	

The delivery period required is measured from the date of receipt of official order after signing of the Contract between the Procuring Entity and the Bidder.

The Project Site for delivery of the goods is the final destination:	ZETDC, Glenville Substation, Bulawayo, Zimbabwe
--	---

ZETDC H/O PROCUREMENT  
**06 OCT 2023**  
 2nd Floor, Southwings, Electricity Centre  
 25 S. Machel Avenue, Harare  
 Tel: 0242 750262  
 procurement@zetdc.co.zw *fw*