

## ZIMBABWE ELECTRICITY TRANSMISSION & DISTRIBUTION COMPANY

HEAD OFFICE ELECTRICITY CENTRE, 25 SAMORA MACHEL AVENUE, HARARE P.O. BOX 377, HARARE TELEPHONE: 774491/9, 774508/35 FAX: 774542/3, 758356

OUR REF: FN/ec		
YOUR REF		
WHEN CALLING WITH REFERENCE TO THIS LETTER PLEASE ASK FOR		
F. Nyamakambo		

06 October 2023

To All Bidders

Dear Sir/Madam

CLARIFICATION NO. 2 FOR TENDER NO. ZETDC/INTER/06/2023 FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF 20MVA, 132/88/11KV POWER TRANSFORMER AT GLENVILLE 88/11KV SUBSTATION

The above subject matter refers.

Attached herewith is **CLARIFICATION NO. 2** for Tender No. ZETDC/INTER/06/2023 for the Supply, Delivery, Installation and Commissioning of 20MVA, 132/88/11kV Power Transformer at Glenville 88/11kV Substation in response to gueries raised by participating Bidders.

Yours faithfully

F. NYAMAKAMBO

**SUPPLY CHAIN MANAGER** 

## TENDER NO. ZETDC/INTER/06/2023 FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF 20MVA, 132/88/11KV POWER TRANSFORMER AT GLENVILLE 88/11KV SUBSTATION

## CLARIFICATION NO. 2

Item	Description/Query from Bidder(s)	ZETDC Response
1.	Protection Relay / Panel	Required on complete panel.
	While reviewing the tender document, we assume that there is a requirement of complete panel for Transformer Differential Protection and Overcurrent & Earth Fault Protection.  Please clarify that M/s ZETDC required on relays or complete panel.	
2.	11kV Indoor Switchgear  While reviewing the tender document, we observe that Technical Specification for 11kV Switchgear is available. But the same item i.e. 11kV Indoor Switchgear is not mentioned in the tender Price Schedule. Please clarify.	Refer to Addendum No. 2 to the Standard Bidding Document (SBD) as regards revised Part 2: Statement of Requirements, 2.1 List of Goods and Price Schedule.  N.B. Part 2: Statement of Requirements, 2.1 List of Services and Price Schedule on page 13 of 110 in the SBD has been amended and replaced by the one under Addendum No. 2 to the SBD.
		11kV Indoor Switchgear Board has been included and clearly stated in the revised Statement of Requirements List of Goods and Price Schedule.  Also amended through Addendum No. 2 to the SBD is 2.2 Delivery Schedule on page 14 of 110 in the SBD.
		Hence, in response to this tender, Bidders must use the revised Part 2: Statement of Requirements, 2.1 List of Goods and Price Schedule and the revised 2.2 Delivery Schedule under Addendum No. 2 to the SBD respectively.
3.	In view of the above and for us to prepare competitive and comprehensive Bid Proposal, we request you to grant additional time of 3 (Three) Weeks from the present bid closing date i.e. 14 <sup>th</sup> September 2023.	The closing date has been extended from 17 October 2023 at 1000 hours to 14 November 2023 respectively as per your request and also to carter for processes related to inclusion of the mandatory site visit for this tender.
		Refer to Closing Date extension letter dated 06 October 2023 on the ZETDC website.
4.	Please confirm the correct impedance value. The technical specification provided has 2 different impedance values. On page 53 of the bidding document, it is given as 6-7% and on page 72 in the Technical Guarantee Schedule it is given as between 11 and 12%.	6-7% is the correct impedance value

ZETDC H/O PROCUREME O 6 OCT ZUZ3 2nd Floor, Switniwing, Electricity Centre 25 S. Machal Avenue, Parare 75 S. Tal. 1242 750262

Procurences (Proc. Co. 7W

Page 1 of 2

- Kindly give some clarity regarding the 20MVA 132-88/11kV transformer to be manufactured:
  - 1. The HV voltage should it be a dual 132-88kV
  - 2. Do you require a distribution transformer or an auto transformer?

Response regarding the 20MVA 132-88/11kV transformer to be manufactured is as follows:

- 1. Yes, the HV voltage should be a dual 132-88kV.
- 2. What is required is a power transformer which is not auto.

## ZETDC H/O PROCUREMENT

O 6 OCT ZUZ3

2nd Floor, Suumiwing, Electricity Centre 25 S. Machel Avenue, Parare Tel: 0242 750262 C. vi procurement@zetdc.co.zw Fusion